

St Florian Parish
Accounts Payable
2626 Poland St
Hamtramck, MI 48212-3423

MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES/BOILER DIVISION
P.O. BOX 30254, LANSING, MICHIGAN 48909
517-241-9334

CERTIFICATE OF BOILER INSPECTION

THE HEREIN DESCRIBED BOILER IS APPROVED FOR OPERATION AT A PRESSURE NOT TO EXCEED THE MAXIMUM OPERATING PRESSURE SPECIFIED HEREON, PROVIDED THE OWNER/USER HAS COMPLIED WITH ALL REQUIREMENTS OF 1965 PA 290, AS AMENDED AND THE RULES AND REGULATIONS PROMULGATED BY THE DIRECTOR OF THE DEPARTMENT. INSTALLATION, REINSTALLATION, ALTERATION, OR REPAIR OF THIS BOILER MUST BE IN STRICT CONFORMITY WITH THE REQUIREMENTS OF 1965 PA 290 AND THE BOILER RULES AND REGULATIONS. THE HOLDER OF THIS CERTIFICATE SHALL NOTIFY THE CHIEF INSPECTOR OF EVERY ACCIDENT INVOLVING PERSONAL INJURY OR DAMAGE TO THIS BOILER.

OWNER/USER

St Florian Parish
Accounts Payable
2626 Poland St
Hamtramck, MI 48212-3423

MANUFACTURER: Pacific

STATE NO: MIR061538

BOILER TYPE: Fire Tube

NB# / MFG#: 206260

YEAR BUILT: 1967

DATE INSP: 08/28/2017

MAX OPR PRESS: 15

EXP DATE: 09/28/2019

LOCATION

St Florian Parish
2626 Poland St
Hamtramck, MI 48212-3423

SV PRESS: 15

INSPECTOR: John Maziarz

Shelly Edgerton

DIRECTOR

David Stenrose

Chief, Boiler Division

BCC-300 (Rev. 1/14)

PLACE IN BOILER ROOM